



Promat



CAFCO® 300

Vermiculite Gypsum Based Wet Mix Spray



CAFCO® 300

Vermiculite Gypsum Based Wet Mix Spray

INTRODUCTION

CAFCO® 300 is a spray or trowel applied, single package factory controlled premix, based on vermiculite and gypsum, for internal use.

CAFCO® 300 is a lightweight coating that provides very efficient fire resistance with minimal thickness to steel and concrete frames, metal floor and roof decks, return air plenums and air handling ductwork.

Structures protected with CAFCO® 300 can provide fire resistance for up to 240 minutes.

Building types that will benefit from the use of CAFCO® 300 include a wide range of educational, leisure and entertainment centres, and commercial projects.



Properties and performance	
Colour and finish	Off white with a monolithic spray texture
Theoretical coverage	217m ² /tonne at 15mm thickness
Number of coats	One or more as required
Cure	By hydraulic set
Initial set	10 to 15 hours at 20°C and 50% RH without accelerator
Density	310kg/m ³ ± 15% without accelerator, approximately 10% less with accelerator in accordance with ASTM E605.
Bond impact	No cracks or delaminations in accordance with ASTM E760
Air erosion resistance	No erosion in accordance with ASTM E859
Compressive strength	1.22kg/cm ² in accordance with ASTM E761
Deflection effect	No spalling, delamination or cracking in accordance with ASTM E759.
Flame spread	Class 0 as defined by Building Regulations
Thermal conductivity	0.078W/mK
Corrosion resistance	Does not promote corrosion of steel and does not require application over primed steel. Please seek structural engineer's advice concerning long term corrosion protection.
pH value	8.0 - 8.5
Fire resistance	Structures protected with CAFCO® 300 have undergone fire resistance tests up to 240 minutes in approved independent laboratories to recognised standards throughout the world, including: <ul style="list-style-type: none"> • Australia (AS1530: Part 4) • UK (BS476: Parts 6, 7 and 21) • USA (ASTM E119) • France (August 1999 Ministry Decree) • Belgium (NBN S21-202) • Germany (DIN 4102: 1977-09 and DIN EN 1363-1:1999-10) • Harmonised European Standard ENV 13381: Part 4 The fire resistance test results relate solely to the constructions tested and test conditions imposed.

QUALITY ASSURANCE

Promat manufactures to a quality system in accordance with ISO 9001:2000 and has received full accreditation to these standards.

Operating to these standards means that all activities, which have a bearing upon quality, are set out in written procedures. Systematic and thorough checks are made on all materials and their usage. Test equipment is subjected to regular checks and is referred back to national standards.

The information given in this data sheet is based on actual tests and is believed to be typical of the product. No guarantee of results is implied however, since conditions of use are beyond our control.



CAFCO® 300

Vermiculite Gypsum Based Wet Mix Spray

Preparation	
Typical substrates	Unprimed and primed steel, concrete structural frames, return air plenums and air handling ductwork.
Substrate preparation	The substrate shall be clean, dry and free from dust, loose mill scale, loose rust, oil and any other condition preventing good adhesion. Application to unprimed steel is acceptable. Where non compatible primers are used, steelwork and concrete substrates should be covered with CAFCO® SBR bonding latex or Caico BONDSEAL® keycoat, prior to the application of CAFCO® 300.
Application	
Initial steps	Application of CAFCO® 300 must be carried out by an applicator recognised by Promat.
Methods	Mix CAFCO® 300 with potable water in a suitable mixer and apply by a spraying machine approved by Promat. CAFCO® 300 may also be float finished using conventional hand tools or spray textured.
Limitations	CAFCO® 300 may be applied when the substrate and air temperatures are at least 4°C and rising, and must be maintained for 24 hours before, during and 24 hours after application. Maximum substrate and air temperature is 45°C. Substrate temperature should be at least 2°C above dew point temperature.

Please refer to the separate publication of CAFCO® 300 application guide for further details or consult your nearest Promat office for specific details pertaining to local conditions.

PACKAGING

20kg bags.

STORAGE

Protect from frost, excessive heat (above 45°C) and strong radiant sunlight.

SHELF LIFE

Maximum 12 months.

ENVIRONMENTAL

Do not discharge into drains, watercourses or soil.



For latest information of the Promat Asia Pacific organisation,
please refer to www.promat-ap.com

ASIA PACIFIC HEADQUARTERS

Promat International (Asia Pacific) Ltd.
Unit 19-02-01, Level 2 PNB Damansara
No.19 Lorong Dungun, Damansara Heights
50490 Kuala Lumpur
MALAYSIA
Tel: +60 (3) 2095 5111
Fax: +60 (3) 2095 6111
Email: spraysinfo@promat-ap.com

AUSTRALIA

Promat Australia Pty. Ltd.
1 Scotland Road
Mile End South, SA 5031
Tel: 1800 PROMAT (776 628)
Fax: +61 (8) 8352 1014
Email: spraysinfo@promat.com.au

New South Wales Office **Promat Australia Pty. Ltd.**

Unit 1, 175 Briens Road
Northmead, NSW 2152
Tel: 1800 PROMAT (776 628)
Fax: +61 (2) 9630 0258
Email: spraysinfo@promat.com.au

Victoria Office

Promat Australia Pty. Ltd.
3/273 Williamstown Road
Port Melbourne, VIC 3207
Tel: 1800 PROMAT (776 628)
Fax: +61 (3) 9645 3844
Email: spraysinfo@promat.com.au

Queensland Office

Promat Australia Pty. Ltd.
Unit 2 Level 1
49 Gregory Tce
Spring Hill, QLD 4000
Tel: 1800 011 376
Fax: 1800 334 598
Email: spraysinfo@promat.com.au

CHINA

Promat China Ltd.
Room 503, Block B, Qi Lin Plaza
13-35 Pan Fu Road
510180 Guangzhou
Tel: +86 (20) 8136 1167
Fax: +86 (20) 8136 1372
Email: spraysinfo@promat-ap.com

Beijing Office

Promat North China
(Division of Promat China Ltd.)
Room 1507 Building 5, SOHO Xiandaicheng
No.88 Jianguo Road, Chaoyang District
100022 Beijing
Tel: +86 (10) 8589 1254
Fax: +86 (10) 8589 2904
Email: spraysinfo@promat-ap.com

For Promat International groups worldwide:
www.promat-international.com

1. This document is produced on the basis of information and experience available at the time of preparation. Promat is constantly reviewing and updating all of its test data and reserves the right to change products and specifications without notice.
2. Promat is not responsible if recipients of fire test reports, assessments or literature incorrectly interpret said contents and use products based on those interpretations.

HONG KONG

Promat International (Asia Pacific) Ltd.
Room 1010, C.C. Wu Building
302-308 Hennessy Road
Wanchai
Tel: +852 2836 3692
Fax: +852 2834 4313
Email: spraysinfo@promat-ap.com

INDIA

Promat International (Asia Pacific) Ltd.
(India Representative Office)
610-611, Ansal Imperial Tower
C-Block, Community Centre
Naraina Vihar, Naraina
110028 New Delhi
Tel: +91 (11) 2577 8413
Fax: +91 (11) 2577 8414
Email: spraysinfo@promat-ap.com

Bangalore Office

Promat International (Asia Pacific) Ltd.
(India Representative Office)
Cabin No.BC-9 & BC-10
Oculus Workspaces, No.66/1, 2nd Floor
Coles Road, Frazer Town
560005 Bangalore
Tel: +91 (80) 4031 4151
Fax: +91 (80) 4125 2135
Email: spraysinfo@promat-ap.com

Mumbai Office

Promat International (Asia Pacific) Ltd.
(India Representative Office)
Stylus Serviced Offices
Ground Floor, Velocity
Phase 1, Logitech Park
Andheri Kurla Road, Andheri East
400072 Mumbai
Tel: +91 (22) 6769 4567
Fax: +91 (22) 6769 4568
Email: spraysinfo@promat-ap.com

MALAYSIA

Promat (Malaysia) Sdn. Bhd.
Unit 19-02-01, Level 2 PNB Damansara
No.19 Lorong Dungun, Damansara Heights
50490 Kuala Lumpur
Tel: +60 (3) 2095 8555
Fax: +60 (3) 2095 2111
Email: spraysinfo@promat-ap.com

SINGAPORE

Promat Building System Pte. Ltd.
10 Science Park Road, #03-14 The Alpha,
Singapore Science Park II
Singapore 117684
Tel: +65 6776 7635
Fax: +65 6776 7624
Email: spraysinfo@promat-ap.com

Your local Promat supplier

