
CERTIFICATE OF APPROVAL

No CF 427

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ETEX BUILDING PERFORMANCE LIMITED

Gordano House, Marsh Lane, Easton-in-Gordano, Bristol, BS20 0NE
Tel: 0800 145 6033

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT	TECHNICAL SCHEDULE
Promaseal Fire Pillows	TS03 Penetration Sealing Systems

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager

Issued: 13th April 2006
Reissued: 24th October 2018
Valid to: 7th May 2023

Page 1 of 4



CERTIFICATE No CF 427

ETEX BUILDING PERFORMANCE LIMITED

Promaseal Fire Pillows

1. This approval relates to the use of Promaseal Fire Pillows for the fire protection where services are penetrating walls and floors. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the thickness and acceptable services for Promaseal Fire Pillows required to provide fire resistance periods in accordance with BS 476: Part 20: 1987 or EN 1366-3: 2009 (as indicated in the Matrix of Approval) of up to 120 minutes for differing services and wall/floor constructions. The scope of certification complies with the guidelines stated in the ASFP Red Book: 3rd Edition for 3rd party certification schemes.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose
3. The product is approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS03
 - iii) A design appraisal against TS03
 - iv) Inspection and surveillance of factory production control
4. The concrete floors and/or masonry or concrete walls shall be at least as thick as the sealing system as shown in the Approval matrix and have at least the same fire rating as that required for the penetration seal.
5. The services which may be fitted through the seals are cables ladders of various sizes and communication cables.
6. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Further Information

Further information regarding the details contained in this data sheet may be obtained from Etex Building Performance Limited (Tel: 0800 145 6033).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel:01925 646777).

CERTIFICATE No CF 427

ETEX BUILDING PERFORMANCE LIMITED

Promaseal Fire Pillows - BS 476: Part 20: 1987 Approval Matrix

Product Name:		Promaseal Fire Pillows				
Coating / WFT:		Not applicable				
Density:		Not applicable				
Orientation	Services	Integrity/ Insulation	Required Pillow Thickness For Fire Resistance Period (minimum)			
			30 mins	60 mins	90 mins	120 mins
Floor	No	Int. & Ins.	150 mm	150 mm	200 mm	200 mm
	Yes	Int. & Ins.	150 mm	200 mm	250 mm	300 mm
	Yes	Int. only	150 mm	150 mm	200 mm	200 mm
Wall	No	Int. & Ins.	150 mm	180 mm	250 mm	300 mm
	Yes	Int. & Ins.	150 mm	200 mm	250 mm	300 mm
	Yes	Int. only	180 mm	180 mm	250 mm	300 mm
Penetrating Services:		Cable ladders and communication cables				
Maximum aperture:		1000 mm by 1000 mm				
Wall/floor thickness:		The floors and walls shall be a minimum of 100mm thick for periods of up to 60 minutes fire resistance and 150 mm (floor) and 200 mm (wall) thick for periods of 90 minutes and 120 minutes fire resistance. The minimum density for the concrete of the floor or wall is 780kg/m ³ and for walls made of concrete blocks is 600kg/m ³ .				
Application Technique:		<p>Floors: Steel mesh (50 mm square with 5 mm wire) is mechanically fixed either to the soffit of the floor or within the reveal of the aperture via vertical returns at the edges of the mesh. The fire pillows are tightly packed into the opening and around the services.</p> <p>Walls: The fire pillows are tightly packed into the opening and around the services (no mesh is required).</p>				
Service Coat-Back :		Not required			U Value:	Not known
Service Support Requirements:		Services should be rigidly supported via steel angles, hangars or channels, not further than 500 mm from the surface of the sealing system on both faces.				
Resistance to Smoke:		Not evaluated by this approval		Weather Capability:	Not evaluated by this approval	
Acoustic Rating:		Not evaluated by this approval		Movement Capability:	Not evaluated by this approval	

CERTIFICATE No CF 427

ETEX BUILDING PERFORMANCE LIMITED

Promaseal Fire Pillows - BS EN 1366-3: 2009 Approval Matrix

Product Name:		Promaseal Fire Pillows		
Element of construction	Services	Additional requirements	Integrity	Insulation
Masonry/ concrete wall min 150 mm thick	Telecom cables up to 21mm Ø (single or bundles up to 100 mm Ø)	None	120 minutes	120 minutes
	Electrical cables up to 21 mm Ø	None	120 minutes	120 minutes
	Electrical cables up to 50 mm Ø	Cables lagged*	120 minutes	90 minutes
	Electrical cables up to 80 mm Ø	Cables lagged*	120 minutes	90 minutes
	Unsheathed wires up to 24 mm Ø	Cables lagged*	120 minutes	120 minutes
	Steel or Copper conduits and tubes up to 16 mm Ø	None	120 minutes	120 minutes
	Plastic (any) conduits and tubes up to 16 mm Ø	None	120 minutes	120 minutes
	Cable tray/ladder up to 300mm wide	None	120 minutes	60 minutes
	Cable tray up to 500 mm wide	None	120 minutes	90 minutes
	54mmØ x 1.0 mm thick copper pipe with 15 mm Armaflex insulation	Pipe lagged***	120 minutes	120 minutes
	108mmØ x 1.5 mm thick copper pipe	Pipe lagged*	120 minutes	90 minutes
	48mmØ x 3.5mm thick mild steel pipe	Pipe lagged**	120 minutes	120 minutes
	113mmØ x 4.5 mm thick copper pipe	Pipe lagged***	120 minutes	120 minutes
	165mmØx5.6mm thick mild steel pipe	None	120 minutes	-
* Lagging:	To be formed from 2 or more pillows stitched together around the service to a minimum length of 300 mm on both sides of the wall/main seal.			
** Lagging:	To be formed from 8mm ceramic fibre blanket 1 to a minimum length of 300 mm on both sides of the wall/main seal.			
*** Lagging:	To be formed from 8mm ceramic fibre blanket 2 to a minimum length of 300 mm on both sides of the wall/main seal.			
Maximum aperture:	1100 mm by 1100 mm			
Walls:	The walls shall be a minimum of 150mm thick and have a minimum density of 760kg/m ³ . The wall shall be classified to EN 13501-2 for at least the required performance period.			
Application Technique:	The fire pillows inserted lengthways to achieve a 300 mm deep seal and tightly packed into the opening and around the services. Smaller pillows are used as appropriate to fill smaller gaps.			
Service Coat-Back :	Not required		U Value:	Not known
Service Support Requirements:	Services should be rigidly supported via steel angles/hangars/channels, not further than 250 mm from the surface of the sealing system, on both faces.			