

# DECLARATION OF PERFORMANCE

Date of issue: 03/02/2020

## No. 1796-CPR-0013-2020/2

1	<b>Unique identification code of the product-type:</b>  <h3 style="text-align: center;">Smoke extraction duct section model: PROMADUCT<sup>®</sup>-500</h3>		
2	<b>Intended uses</b> smoke extraction ducts sections are intended to use in smoke and heat control systems. They are intended for multi fire compartments, in 4-sided and 3-sided horizontal and vertical configurations with 50mm of Promatect-L500.		
3	<b>Name and contact address of the manufacturer:</b> Promat Techniczna Ochrona Przeciwpożarowa Sp. z o.o. ul. Przeclawska 8 03-879 Warszawa Poland www.promatop.pl		
4	<b>Authorised representative:</b> N/A		
5	<b>System or systems of Assessment and Verification of Constancy of Performance (AVCP):</b> System 1		
6a	<b>The construction product is covered by a harmonised standard (hEN) – EN 12101-7</b>		
6b	Notified product certification body: No. 1796 Fire Research Centre of the Fire and Rescue Department of the Republika of Lithuania  Certificate of Constancy of Performance: 1796-CPR-0013		
7	<b>Declared performance</b>		
	Essential characteristics	AVCP systems	Performance
			Harmonised technical specification
	<b>BWR1: Mechanical resistance and stability: not applicable.</b>		
	<b>BWR2: Safety in the case of fire:</b>		
	Resistance to fire:	1	EI 120 (ve-ho) S1500multi
			EN 12101-7 EN 13501-4

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

The reader of this document is invited to visit the website "[www.promatop.pl](http://www.promatop.pl)" to review the latest version of this DoP.

The Safety Data Sheets (SDS) of components of PROMADUCT®-500 are available on request.

Signed for and on behalf of the manufacturer by:

Name: Elżbieta Mazur  
Function: Technical Director, Promat Techniczna Ochrona Przeciwpożarowa Sp. z o.o..

Warsaw, 03/02/2020.

Signature:

**Promat**  
Techniczna Ochrona Przeciwpożarowa Sp. z o.o.  
ul. Przecławskiego 8, 03-879 Warszawa  
Dyrektor Techniczny  
  
mgr inż. Elżbieta Mazur